

111年污水廠水質統計表

	放流水水質標準	6-9	<35	-	30	100	30	-	-	50	4
採樣日期	水質項目	pH	水溫	導電度	懸浮固體	化學需氧量	生化需氧量	大腸桿菌群	氨氮	硝酸氮	正磷酸鹽
	單位		°C	µmho/cm	mg/L	mg/L	mg/L	CFU/100ml	mg/L	mg/L	mg/L
111.05.11	進流水	7.8	25.8	687	41.5	64.5	19.4	5.E+06	-	-	-
	放流水	8.1	25	546	13.2	12	3.2	17,000	9.18	3.63	0.769
	去除率%				68	81	84	100			
	中水出水水質	8			5.9	42.2	10.5	1,700			
111.06.21	進流水	7.6	28.9	692	8.4	32.1	9.7	6.E+05			
	放流水	7.4	29.4	621	5.1	16.9	7.4	830	9.06	10.9	1.88
	去除率%				39	47	24	100			
111.07.13	進流水	8.3	27.1	561	4.5	76	22.5	6.E+04	-	-	-
	放流水	8.1	27.5	534	4.2	52	13.1	3,000	2.06	23.6	1.26
	去除率%				7	32	42	95			
	中水出水水質	8.2		402	2.4	12	3.2	1,500			
111.09.13	進流水	7.7	24.9	656	33	51.8	13	7.E+05	-	-	-
	放流水	7.6	24.8	508	3.4	12.8	3.1	85	<0.1	8.5	0.702
	去除率%				90	75	76	100			
	中水出水水質	8		461	3.4	39.8	9.5	40			
111.11.08	進流水	7.7	27.2	747	26.5	104	35.4	6.E+06			
	放流水	7.7	27.4	786	9	41	9.4	60,000	37.1	0.21	3.09
	去除率%				66	61	73	99			
111.11.21	進流水	7.7	21.4	774	21.2	73.3	19.6	8.E+05	-	-	-
	放流水	7.8	20.8	622	6.4	6.4	2.2	3,800	0.95	6.46	1.6
	去除率%				70	91	89	100			
	中水出水水質	7.8		312	2	10.4	2.6	<10			