

112年污水廠水質統計表

	放流水水質標準	6-9	<35	-	30	100	30	-	-	50	4
採樣日期	水質項目	pH	水溫	導電度	懸浮固體	化學需氧量	生化需氧量	大腸桿菌群	氨氮	硝酸氮	正磷酸鹽
	單位		°C	µmho/cm	mg/L	mg/L	mg/L	CFU/100ml	mg/L	mg/L	mg/L
112.01.04	進流水	7.6	21.5	923	52	104	43.4	5.E+06	-	-	-
	放流水	7.5	21.4	858	6.1	16	4.6	28,000	22.9	16.6	1.57
	去除率%				88	85	89	99			
	中水出水水質	7.9		429	4	31.2	8.7	40,000			
112.03.08	進流水	7.7	22.1	906	27	171	60.5	9.E+06			
	放流水	7.5	22.2	709	5.9	15.1	3.9	6,200	20.7	9.73	2.3
	去除率%				78	91	94	100			
	中水出水水質	7.8	22.2	511	4.8	13.6	3.4	<10			
112.05.09	進流水	7.6	24.2	905	79.5	183	70.6	4.E+07			
	放流水	7.5		708	11.1	35.1	8.6	45,000	13.5	13	3.5
	去除率%				86	81	88				
	中水出水水質	7.9		512	8.5	32.7	8.1	<10			
112.05.09	進流水	7.6	27	913	67.5	168	84.6	3,700,000			
	放流水	7.2	28.8	812	9.6	24.8	6.1	41,000	18	5	3
	去除率%				86	85	93				
	中水出水水質	7.6	26.9	454	4	38	10	10			
112.07.05	進流水	7.4	31	861	8.7	53	14.3	2.E+04			
	放流水	6.8	31.6	754	3.8	41	11.3	<10	0.18	4.38	3.39
	去除率%				56	23	21				
	中水出水水質	7.7		478	3.4	34.5	9	<10			
112.09.12	進流水	7.6	24.8	889	32.5	183	76.5	8.E+07			
	放流水	7.2		359	5.5	23.1	5.8	15,000	0.09	11.4	1.36
	去除率%				83	87	92				
	中水出水水質	7.6		128	3.1	51.8	14.3	<10			
112.11.02	進流水	7.5	26.7	835	26.6	146	49.4	6.E+05			
	放流水	7	25.1	667	4.1	34.5	6	8,500	50.5	10.6	3.83
	去除率%				85	76	88				
	中水出水水質	8	26.1	365	5.2	27.3	7	15			
112.11.06	進流水	7.8	28.7	986	22.5	136	48	4.E+06			
	放流水	7.4	27.3	849	5.3	24	6.3	4.E+04	10	11	3.79
	去除率%				76	82	87				
	中水出水水質	7.3	27.8	911	3	18	4	20			