

113年污水廠水質統計表

	放流水水質標準	6-9	<35	-	30	100	30	-	-	50	4
採樣日期	水質項目	pH	水溫	導電度	懸浮固體	化學需氧量	生化需氧量	大腸桿菌群	氨氮	硝酸氮	正磷酸鹽
	單位		°C	µmho/cm	mg/L	mg/L	mg/L	CFU/100ml	mg/L	mg/L	mg/L
113.01.03	進流水	7.6	24.6	1200	79	171	64.2	4.E+06	-	-	-
	放流水	6.6	24.1	658	5.5	87.6	25.6	3,200	2.06	23.6	4.83
	去除率%				93	49	60	100			
	中水出水水質	9		479	21.8	106	36.4	<10			
113.03.05	進流水	7.2	24.6	972	16	136	47.6	2.E+07			
	放流水	7	24.9	622	6.9	24.6	6.2	6,700	5.72	15.2	6.03
	去除率%				57	82	87				
	中水出水水質	7.5	24.6	483	3.2	41.3	10.4	<10			
113.05.07	進流水	7.6	30.6	918	27	211	105	2.E+07			
	放流水	7.6	27.2	473	0.6	14.3	3.6	2,700	2.11	2.64	0.94
	去除率%				98	93	97				
	中水出水水質	7.7	30.4	473	14.8	37.4	11.2	<10			
113.05.09	進流水	7.7	26.3	982	49	294	128	3,900,000			
	放流水	7.3	26.4	600	9	24.4	20.5	<10	0	14	1
	去除率%				82	92	84				
	中水出水水質	7.3	26.4	464	8	36	28	5,000			
113.07.16	進流水	7.2	27.7	658	13.5	67.5	20.4	4.E+04			
	放流水	7.1	28.4	627	4.9	17.5	4.4	3,400	0.17	3.59	3.76
	去除率%				64	74	78				
	中水出水水質	7.5	27.4	432	5.3	8.2	5.5	<10			
113.09.12	進流水	7.5	25.5	1010	38.1	166	82.2	3.E+07			
	放流水	7.1	25.5	518	6.1	12.8	3.1	4,900	1.66	4.61	2.02
	去除率%				84	92	96				
	中水出水水質	7.8	25.5	382	5.5	7.3	6.2	<10			
113.11.05	進流水	7.8	30.7	888	20.3	163	66.7	3.E+07			
	放流水	7.6	29.3	512	3.7	13.6	3.3	3,400	6.41	18.9	1.03
	去除率%				82	92	95				
	中水出水水質	7.1	27.1	313	3	16	4.5	<10			
113.11.11	進流水	7.7	26.4	1110	40.5	144	52	3.E+07			
	放流水	7.4	26.1	546	8.5	7.2	2.9	5.E+03	3	14	3.95
	去除率%				79	95	94				
	中水出水水質	7.5	26.2	359	10	18	4	<10			