

114年污水廠水質統計表

	放流水水質標準	6-9	<35	-	30	100	30	-	-	50	-
採樣日期	水質項目	pH	水溫	導電度	懸浮固體	化學需氧量	生化需氧量	大腸桿菌群	氨氮	硝酸氮	正磷酸鹽
	單位		°C	µmho/cm	mg/L	mg/L	mg/L	CFU/100ml	mg/L	mg/L	mg/L
114.01.8	進流水	7.4	23	982	76.5	202	105	4.E+07	-	-	-
	出流水	7	23.2	705	8	32.9	3.4	120	0.94	19.5	3.28
	去除率%				90	84	97	100			
	中水出水水質	7.4	23.1	441	1.62	9.41	<2.0	<10			
114.03.12	進流水	7.3	27.9	381	45.5	190	42.5	6.E+06	-	-	-
	出流水	7.2	27.9	723	3.8	29.2	2.6	160	13.1	8.67	3.18
	去除率%				92	85	94	100			
	中水出水水質	7.3	28.2	469	6.1	32.4	14.2	<10			
114.05.06	進流水	7.8	28.4	889	53	140	49.8	3.E+07	-	-	-
	出流水	7.6	28.3	820	3.3	40.8	6.8	2,700	19.7	10.8	13.6
	去除率%				94	71	86	100			
	中水出水水質	7.9	28.3	532	5.3	11.2	2.7	<10			
114.05.16	進流水	7.5	28.1	581	45.5	194	48.5	2,700,000	-	-	-
	出流水	7.8	28.1	728	3.8	39.2	8.6	260	13	8.67	3.18
	去除率%				92	80	82	100			
	中水出水水質	7.3	28.2	469	4.3	32.4	2.2	<10			
114.07.18	進流水	7.5	28.1	573	50.9	256	49.7	4.E+06	-	-	-
	出流水	7.3	28.1	732	6.7	28.8	6.7	270	12.3	9.8	3.72
	去除率%				87	89	87	100			
	中水出水水質	7.6	28.1	674	10.4	35.3	5.7	<10			
114.09.04	進流水	7.4	29.4	773	27.9	153	38.7	3.E+05			
	放流水	7.1	29.3	757	7.8	28.3	9.2	220	4.7	4.3	3.29
	去除率%				72	82	76	100			
	中水出水水質	7.4	29.2	474	7.4	38.7	8.3	<10			
114.11.04	進流水	7.6	28.8	818	23.8	121	48	2.E+07	-	-	-
	出流水	7.4	26.7	442	4.4	10.4	2.8	290	2.92	9.38	3.47
	去除率%				82	91	94	100			
	中水出水水質	7.5	25.2	524	6.2	14.5	4.1	<10			
114.11.26	進流水	7.6	29.4	773	29.4	143	42.7	2.E+07			
	放流水	7.2	25.7	589	11.1	28.1	8.2	3.E+02	3.4	6.8	3.51
	去除率%				62	80	81	100			
	中水出水水質	7.6	25.5	452	4.2	21.7	6.6	<10			